



Notified Body No. 0370

CERTIFICATE



No. **0370-CPR-1866**

CERTIFICATE OF CONSTANCY OF PERFORMANCE

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

FIRE DETECTION AND FIRE ALARM SYSTEMS:

- **PART 11:** MANUAL CALL POINTS
- **PART 17:** SHORT-CIRCUIT ISOLATORS

MODEL: **MAD-450-I** (ADDRESSABLE MANUAL CALL POINTS WITH SHORT CIRCUIT ISOLATOR)

Place on the market under the name of:

DETNOV SECURITY, S.L.

C/ DE LA CIÈNCIA, 30
08840 VILADECANS (BARCELONA - SPAIN)

And produced in the manufacturing plant:

C/ DE LA CIÈNCIA, 30
08840 VILADECANS (BARCELONA - SPAIN)

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standards

EN 54-11:2001, EN 54-11:2001/A1:2005; EN 54-17:2005, EN 54-17:2005/AC:2007

under system 1 are applied and that **the product fulfils all the prescribed requirements set out above.**

This certificate was first issued on 14th November 2014 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly. It is confirmed on 13th September 2019.

The monitoring assessment will be done before September 2020

Bellaterra, 13th September 2019


LGAI Technological Center, S.A.

Xavier Ruiz Peña
Managing Director, Product Conformity B.U.

This document is not valid without its technical annex, whose number coincides with the number of certificate



TECHNICAL ANNEX 0370-CPR-1866

CERTIFICATE OF CONSTANCY OF PERFORMANCE

Annexes according to **EN 54-11:2001, EN 54-11:2001/A1:2005**

ESSENTIAL CHARACTERISTICS	CLAUSES IN THIS EUROPEAN STANDARD	MANDATED LEVEL(S) OR CLASS(ES)
Marking and data	4.2	PASS
Normal condition	4.3.1	PASS
Alarm condition	4.3.2	PASS
Indicators for alarm condition	4.4	PASS
Reset facility	4.5	PASS
Test facility	4.6	PASS
Shape, dimensions and colors	4.7.2	PASS
Symbols and lettering	4.7.3	PASS
Protection against accidental operation	4.7.4	PASS
Environment category	4.7.5	PASS
Additional requirements for software controlled manual call points	4.8	NA
Operational performance test	5.2	PASS
Function test	5.3	PASS
Test facility test (operational)	5.4	PASS
Reliability test (endurance)	5.5	PASS
Variation of supply parameters	5.6	PASS
Dry heat (operational)	5.7	PASS
Dry heat (endurance)	5.8	NA
Cold (operational)	5.9	PASS
Damp heat, cyclic (operational)	5.10	PASS
Damp heat, cyclic (endurance)	5.11	NA
Damp heat, steady state (endurance)	5.12	PASS
SO2 corrosion (endurance)	5.13	PASS
Shock (operational)	5.14	PASS
Impact (operational)	5.15	PASS
Vibration, sinusoidal (operational)	5.16	PASS
Vibration, sinusoidal (endurance)	5.17	PASS
Electromagnetic compatibility (EMC) (operational)	5.18	PASS
Enclosure protection	5.19	NA

PASS; NPD = No Performance Determined, NA = Not Apply



TECHNICAL ANNEX 0370-CPR-1866

CERTIFICATE OF CONSTANCY OF PERFORMANCE

Annexes according to **EN 54-17:2005, EN 54-17:2005/AC:2007**

ESSENTIAL CHARACTERISTICS	CLAUSES IN THIS EUROPEAN STANDARD	MANDATED LEVEL(S) OR CLASS(ES)
Compliance	4.1	PASS
Integral status indication	4.2	PASS
Connection of ancillary devices	4.3	NA
Monitoring of detachable short-circuit isolators	4.4	NA
Manufacturer's adjustments	4.5	PASS
On-site adjustments	4.6	NA
Marking	4.7	PASS
Data	4.8	PASS
Additional requirements for software controlled short-circuit isolators	4.9	NA
Reproducibility	5.2	PASS
Variation in supply voltage	5.3	PASS
Dry heat (operational)	5.4	PASS
Cold (operational)	5.5	PASS
Damp heat, cyclic (operational)	5.6	PASS
Damp heat, steady state (endurance)	5.7	PASS
Sulphur dioxide (SO ₂) corrosion (endurance)	5.8	PASS
Shock (operational)	5.9	PASS
Impact (operational)	5.10	PASS
Vibration, sinusoidal (operational)	5.11	PASS
Vibration, sinusoidal (endurance))	5.12	PASS
Electromagnetic Compatibility (EMC), Immunity tests (operational)	5.13	PASS

PASS; NPD = No Performance Determined, NA = Not Apply

